

Missouri
Department
of Transportation



Dan Niec, District Engineer

North Central District
902 North Missouri St.
P.O. Box 8
Macon, MO 63552
(660) 385-8246
Fax (660) 385-1707
Toll free 1-888 ASK MoDOT
<http://www.modot.mo.gov>

ADDENDUM 001
REQUEST FOR QUOTATION NUMBER: D208-057-RE

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with the quotation. The following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type):	Name and Title of Department Authority: Betty Dwiggins Senior General Services Technician
Bidder Signature (Signature of person authorized to sign)	Missouri Department of Transportation <i>Betty Dwiggins</i> (Authorizing Signature)
Date Signed:	Date Signed: Thursday, July 3, 2008

This signed addendum MUST be included with your response to the RFB.

For all interested vendors:

1. On page 1 (one) of the RFQ D208-057-Fuel Tank Installation should read

2.1 Tank is a 5000 gallon tank, normal capacity **SWRI Fire rated to meet 2000 degrees / 2 hr fire rating per NFPA** code cylindrical double wall saddle or rectangular tank, 8' diameter X 14' length, white color with at least one spare 4" FNPT opening (plug-for future use). Air test tank per manufacturer recommendations after setting but before installing accessories. Tank to be anchored to concrete pad furnished by MoDOT.